



कुळगांव बदलापूर नगरपरिषद



नगरपालिका कार्यालय, व. गांवी नगर, बदलापूर रोड, कोल्हापूर (क.) कुळगांव, पिन - ४२१००३, ता. अंबरनाथ जि. ठाणे.
ई-मेल :- covid.kulgaonbadalapurmaharashtra.gov.in, फोननं. : kbmc, १२०३३

जावक क्र :- कु.ब.न.प / अग्नि/३२३४८०१/५५ /२०२६-२७

दिनांक :- २७/०५/२०२६

प्रति,

प्राचार्य, रोझरी हायस्कूल,
यादव नगर, उल्हासनदी जवळ,
बदलापूर गांव रोड, बदलापूर पश्चिम.

विषय :- अग्निशमन विभागाचा ना - हरकत दाखला नुतनीकरण.

संदर्भ :- १) रोझरी हायस्कूल, प्राचार्य, सौ. सुमिता वाडे यांचा दि. २७/०४/२०२६ रोजीचा अर्ज.
२) जा.क्र. कुबनप / अग्नि / ७६ / २०२३ - २४ दि. ०५ / १० / २०२३ अन्वये.
३) शासनमान्य लायसन्स अधिकरण मं. सेफस्टेक फायर सेफ्टी सर्विसेस यांचे नमुना 'ब' प्रमाणपत्र.
४) अग्निशमन विभागाने दि. १४/०५/२०२६ केलेली तपासणी व चाचणी.

महोदय,

कुळगांव बदलापूर नगरपरिषद हद्दीतील बदलापूर पश्चिम मौजे बदलापूर गांव रोड, विभागातील स.नं. १९० हिस्सा नं. ८ क १ व ९ या भूखंडावर बांधलेल्या तळ + १ मजलीच्या दोन शैक्षणिक इमारतींतील असलेल्या रोझरी हायस्कूलमध्ये लावलेल्या आग प्रतिबंधक उपाययोजनाच्या दृष्टीने पाहणी केली असता तपासणी दिवशी यंत्रणा लावल्याचे व कार्यन्वित असल्याचे खालील अटी शर्ती अधीन राहून दाखल्याचे नुतनीकरण करून देण्यात येत आहे.

- १) शाळेसाठी आवश्यक त्या शासकीय / निमशासकीय परवानगी घेण्याची जबाबदारी शाळा व्यवस्थापनाची असेल.
- २) शाळेत लावलेल्या आग प्रतिबंधक यंत्रणेची नियमित देखभाल दुरुस्ति ठेवावी.
- ३) शाळेतील अग्निशमन यंत्रणा हाताळणीचे प्रशिक्षण सर्व स्टाॅफला यंत्रणा बसविणाऱ्या एजन्सी मार्फत द्यावे.
- ४) प्रत्येक वर्षी जानेवारी व जुलै महिन्यात लायसन्स एजन्सी मार्फत अग्निशमन यंत्रणांची तपासणी व चाचणी करून नमुना ब प्रमाणपत्र घेणे बंधनकारक आहे.
- ५) सुरक्षा कॅबिन मध्ये महत्वाचे दूरध्वनी क्र. ठळक अक्षरात प्रदर्शित करावेत.
- ६) फायर पंप Alternate विद्युत पुरवठा जोडण्यास यावा.
- ७) वर्षातून किमान एकदा Mock drill चे आयोजित करावे.
- ८) गच्चीवरील फायर सिस्टमचा पाण्याचा मुख्य बॉल्व्ह सदैव चालू स्थितीत ठेवावा.
- ९) शाळेच्या इमारतीत किचन / पॅन्ट्री करू नये.
- १०) सदरचा दाखला दिलेल्या तारखेपासून १ वर्षापुरता मर्यादित असून दरवर्षी दाखल्याचे नुतनीकरण करणे बंधनकारक आहे.
- ११) स्थळाचे एकूण क्षेत्रफळ _____ स्केअरफुट असून नुतनीकरण नाहरकत दाखला फी रु. ५०००/- पावती क्र. ६५७३५ अन्वये दि. २७/०५/२०२६ भरण्यात आली आहे.



Digitally signed by
HARIDAS RAMCHANDRA SURYAWANSHI
Date: 27-05-2026 12:36:18

अग्निशमन अधिकारी
कुळगांव बदलापूर नगरपरिषद
कुळगांव

Fire Safety Certificate / Renewal Letter

(From Kulgaon Badlapur Municipal Council)

Date: 27/05/2026

Reference No.: Fire/3234801/55/2026-27

To.

The Principal,
Rosary High School,
Yadav Nagar, near Ulhasnadi,
Badlapur Gaon Road, Badlapur (West)

Subject: Renewal of Fire Department No Objection Certificate (NOC)

Reference:

1. Application submitted by Rosary High School dated 27/04/2026
2. Previous Fire NOC issued on 05/10/2023
3. Standard Fire & Safety compliance certificate (Form 'B')
4. Inspection conducted by Fire Department on 14/05/2026

Respected Sir/Madam,

Following the inspection conducted by the Fire Department of Kulgaon Badlapur Municipal Council, the fire safety arrangements installed in your school building (Ground 2 floors) located at Badlapur (West) have been verified.

Based on the inspection and subject to compliance with the following conditions, the **Fire NOC is hereby renewed.**

Conditions:

1. The school management shall obtain all necessary government and local authority permissions.
2. Fire safety equipment installed in the school must be **regularly maintained and kept functional.**
3. All staff must be **trained in handling fire safety equipment through authorised agencies.**
4. Fire safety systems must be **inspected annually (Jan-June period) and certified by authorised agencies.**

MY APPOINTMENT
EXPIRES ON 06/01/2030



ATTESTED BY ME

Sunil N. Shah
Adv. (Dr.) **SUNIL NAVANTILAL SHAH**
Ph.d(Law), M.Sc., LL.B., LL.M.(Crimin.), LL.M.(IPR)
Advocate & Notary, Govt. of India
Regn. No. 30512 Dt. 5-1-25 Mumbai
6/C/205, Silver Oak, S. Panvelkar
Dattawadi, Badlapur (E), Thane

5. Important emergency contact numbers must be **clearly displayed** in the premises.
6. Fire pump must be connected to an **alternate power supply**.
7. At least **one mock drill per year** must be conducted.
8. Water supply valves of the fire system must be kept **operational at all times**.
9. No obstruction/storage should be done in school passages or premises that may hinder safety.
10. The renewal is valid for **one year from the date of issue** and must be renewed annually.
11. The premises area is recorded as 16470 sq. ft.
12. Renewal fee of ₹5000 has been paid (Receipt No. 65735 dated 27/05/2026).

Issued by:

Fire Officer

Kulgaon Badlapur Municipal Council

(Official Seal & Signature)



ATTESTED BY ME

Sunil Navanilal Shah

Adv. (Dr.) SUNIL NAVANILAL SHAH
Ph.D(Law), M.Sc., LL.B., LL.M.(Criminology), LL.M.(IPR)
Advocate & Notary, Govt. of India
Regn. No. 30512 Dt. 8-1-25 Mumbai
6/C/205, Silver Oak, S. Panvelkar
Dattawadi, Badlapur (E), Thane

**MY APPOINTMENT
EXPIRES ON 06/01/2030**